

SUPPLEMENTAL/BID BULLETIN NO.3

To the Bid Documents for the

**SUPPLY, DELIVERY, INSTALLATION, TEST AND COMMISSIONING OF 3 x 1,200 KW
GENSETS FOR PULANGLUPA DPP AND 4 X 1,200 GENSETS FOR MAMBURAO DPP, 7
X 1.5 MVA POWER TRANSFORMERS AND POWER/INSTRUMENT CABLES
INCLUDING ASSOCIATED EQUIPMENT (SPUGLuzP08Z02Sre) - REBIDDING**

March 4, 2009

All holders of the above tender are hereby informed of the following changes/improvements on some of the provisions of the bid documents:

1. A copy of “**Affidavit of Site Inspection (Form NPCSF-INFR-29)**” as required in the Checklist of Technical and Financial Envelope Requirements for Bidders (Standard Form Number: NPCSF-GOOD-12) of Part VI – Bidding Forms – Section BF.3, is hereby attached.
2. Part V-Technical Provisions, Clause MW-3.2, page V-MW-3, 1st paragraph, 4th line, revise “....**turbocharger and with air to air charged cooler,**...” to “....**turbocharger and with air to air or water to air charged cooler**...”.
3. Part V – Technical Provisions, Clause GW-4.3, item a), change “**Continuous Duty**” to “**Prime Duty**”.
4. Part VII – Technical Data Sheets, Item A1.1, page VII-TDS-1, change “**(Continuous or prime duty)**” to “**(prime duty)**”.

For the guidance of all concerned.

(Sgd.)

E. P. ANGULUAN

Vice President and Chairman
Bids and Awards Committee