



NBC

st 8/24

AUG 17 2009

REPUBLIC OF THE PHILIPPINE
NATIONAL POWER CORPORATION
Palinpinon, Valencia
Oriental Negros

PD 090721 - NE 6797

PURCHASE REQUISITION

PR NO.
GE-PGP09-012
Use this Number
in all communication

026A-8

Requisitioning Office: PALINPINON GEOTHERMAL POWER PLANT
Cost Center Number: 6545005 Local: _____
GL No.: _____ OE No.: Spares
WO No.: _____ JO No.: _____

Date: 02/03/09
Date Needed: 09/03/09
Deliver to: PGPP Warehouse
Date PR Rcvd. by Proc Office: _____

ITEM NO.	NSN	COMPLETE DESCRIPTION/SPECIFICATION	QUANTITY	U/M	ESTIMATED COST	ASSIGNED PO/IO NO.
1	N00000047	CONTACTOR, ACCELERATING , three point box starting contactor for Emergency Oil Pump Motor w/ dynamic braking	1	ASSY	2,900,000.00	
					PHP	2,900,000.00

SPECIFICATIONS:

- Type: NC 225 A1/50
- Rated voltage : 500 VDC
- Rated current : 50 amps
- Lightning impulse withstand voltage : 600V
- Power frequency withstand voltage : 500V
- Rated opening time : 30ms
- Rated closing time : 100ms
- Motor : 2.5KW DC compound, 125 VDC
- Closing/starting sequence : O-O 0.3s-CO-1m-CO

NOTES:

1. Winning bidder shall conduct field installation and test & commissioning.
2. Bidders shall submit clear copy of brochures, detailed circuit diagrams indicating the controller with function on the following sequence:
 - 2.1 Auto and Manual Operation.
 - 2.2 Operates in the absence of AC supply
 - 2.3 Operates when bearing oil pressure drops below 1 Ksc
3. Bidders shall conduct site inspection and submit certificate of site inspection during bidding.

Approved for purchase:

[Signature]
O. C. LORICO
VP - Luzon & Visayas Generation

Certification of Stock Non-Availability

[Signature]
JULITO M. EUMAGUE, JR.
Property Officer A

PURPOSE/REMARKS : For replacement / installation at Nasuji Modular Plant as replacement of defective controller and accessories of Emergency Oil Pump Motor.

Attachments :

Requisitioned by :
MACARIO T. CURATIVO
Print Name & Position Date
Div. Manager, Maintenance

Approved for Purchase :
RICHARD R. MANZANO
Print Name & Position Date
Acting Plant Manager, PGPP

Section VII. Technical Specifications

Inquiry No. :
P.R. No. : GE - PGP09- 012

Technical Specifications

Bidders must state here either "Comply" or "Not Comply" against each of the Individual parameters of each Specification stating the corresponding performance parameter of the equipment offered. Statements of "Comply" or "Not Comply" must be supported by evidence in a Bidders Bid and cross-referenced to that evidence. Evidence shall be in the form of manufacturer's un-amended sales literature, unconditional statements of specifications and compliance issued by the manufacturer, samples, independent test data etc., as appropriate. A statement that is not supported by evidence or is subsequently found to be contradicted by the evidence presented will render the bid under evaluation liable for rejection. A statement either in the Bidders statement of compliance or the supporting evidence that is found to be false either during Bid evaluation, post -qualification or the execution of the Contract may be regarded as fraudulent and render the Bidder or supplier liable of prosecution subject to the provisions of ITB Clause 3.1 (a.2) and/ or GCC/Clause 2.1 (a.2).

Item	Specification	Statement of Compliance Comply?
1	<ul style="list-style-type: none"> - Three point box starting for contactor for Emergency Oil Pump Motor w/ dynamic braking - Type: NC 225 A1/50 - Rated Voltage : 500 VDC - Rated Current : 50 amps - Lightning impulse withstand voltage : 600 V - Power frequency withstand voltage : 500 V - Rated opening time : 30 ms - Rated closing time : 100 ms - Motor : 2.5 KW DC compound, 125 VDC - Closing/starting sequence : O-O 0.3s - CO - 1m - CO 	
	NOTES:	
	1. Winning bidder shall submit conduct field installation and test & commissioning.	
	2. Bidders shall submit clear copy of brochures, detailed circuit diagrams indicating the controller will function on the following sequence:	
	2.1 Auto and Manual Operation	
	2.2 Operates in the absence of AC supply	
	2.3 Operates when bearing oil pressure drops below 1 ksc	
	3. Bidders shall conduct site inspection and submit certificate of site inspection during bidding.	
	Validity Period : 120 days	
	Terms of Payment : 30 days	
	Delivery Period : 2 months	
	Warranty : one (1) year	