



REPUBLIC OF THE PHILIPPINES
 NATIONAL POWER CORPORATION
 Thermal Generation Power Plant
 Barge No. 101

PR NO.
 TE-B0109-105
 Use this Number
 in all communication

PURCHASE REQUISITION

*uploaded 9/11/09
 029D.1*

Requisitioning Office : POWER BARGE 101
 Cost Center Number : 5803310 Local : _____
 GL No. : _____ OE No.: CAPEX
 WO No. : _____ JO No. : _____

Date : 03/23/09
 Date Needed : 09/30/10
 Deliver to : PB101 - Bo. Obrero, Iloilo City
 Date PR Rcvd. by Proc Office: _____

ITEM NO.	NSN	COMPLETE DESCRIPTION/SPECIFICATION	QUANTITY	U/M	ESTIMATED COST	ASSIGNED PO/IO NO.
1	N00000690	PUMP SEA WATER COOLING W/ MOTOR SEE ATTACHED SPECS:	1	ASSY	<u>10,000,000.00</u>	
2	N00000691	PUMP SEA WATER SERVICE W/ MOTOR SEE ATTACHED SPECS:	1	ASSY	6,000,000.00	
					PHP	<u>16,000,000.00</u>

Requirements:

- Interested bidders should conduct actual site inspection to view the actual appearance of the equipment.
- Supplier should present authority to bid/sell from O M.
- Winning bidder should provide certificate of origin and warranty of one (1) year during delivery.

Approved:

[Signature]
D. S. SEDILLA
 VP - Visayas Generatio
 BCFTPP & Bacman GPP

[Signature]
 Certification of Stock Non-Availability
ERNESTO P. VILLAS
 Property Officer C

PURPOSE/REMARKS Intended for replacement of defective Sea Water Service Pump and Sea Water Cooling Pump of PB101.

Attachments :

Requisitioned by :

[Signature]
GERSON S. REVILLES

Print Name & Position
 O/M Supt. A, PB101

Date

Approved for Purchase :

[Signature]
ADAM T. POGOY

Print Name & Position
 Manager, PB101

Date

Section VII. Technical Specifications

Inquiry No. :
P. R. No. : TE-B0109-105

Technical Specifications

Bidders must state here either "Comply" or "Not Comply" against each of the individual parameters each Specification stating the corresponding performance parameter of the equipment offered. Statements of "Comply" or "Not Comply" must be supported by evidence in a Bidders Bid and cross-referenced to that evidence. Evidence shall be in the form of manufacturer's un-amended sales literature, unconditional statements of specification and compliance issued by the manufacturer, samples, independent test data etc., as appropriate. A statement that is not supported by evidence or is subsequently found to be contradicted by the evidence presented will render the Bid under evaluation liable for rejection. A statement either in the Bidders statement of compliance or the supporting evidence that is found to be false either during Bid evaluation, post qualification or the execution of the Contract may be regarded as fraudulent and render the Bidder or supplier liable for prosecution subject to the provisions of ITB Clause 3.1 (a.2) and/or GCC Clause 2.1(a.2).

Item	Specification	Statement of Compliance
1	Pump, sea water cooling with motor, type: Vertical motor driven with self priming centrifugal pump (14x14 DV-A-NV-F), capacity: 1,120 mp/h total head: 20 meters, 1,750 RPM, 100 KW, direct coupled, sealing: packing, rotation: clockwise viewed from coupling side, branches: (Suc x Del): 350mm x 350mm, water test pressure: 4 kgf/cm ² g	Comply.
2	Pump, sea water cooling with motor, type: Vertical motor driven with self priming centrifugal pump (5x4 VH-NV-F), capacity: 120 mp/h total head: 30 meters, 1,750 RPM, 18.5 KW, direct coupled, sealing: packing, rotation: clockwise viewed from coupling side, branches: (Suc x Del): 125mm x 100mm, water test pressure: 4 kgf/cm ² g	Comply
	Validity Period : 60 days	
	Terms of Payment : 30 days	
	Delivery Period : 60 days	
	Delivery Point : PB 101, Iloilo City	
	Warranty : One (1) year	