

## SUPPLEMENTAL/BID BULLETIN NO. 2

To the Bid Documents for the

### **SUPPLY, DELIVERY, INSTALLATION, TEST AND COMMISSIONING OF 3 x 1,200 KW GENSETS FOR PULANGLUPA DPP AND 4 X 1,200 GENSETS FOR MAMBURAO DPP, 7 X 1.5 MVA POWER TRANSFORMERS AND POWER/INSTRUMENT CABLES INCLUDING ASSOCIATED EQUIPMENT (SPUGLuzP08Z02Sre) - REBIDDING**

February 23, 2009

---

All holders of the above tender are hereby informed of the following changes/improvements on some of the provisions of the bid documents:

1. Clause GW-14.0, page V-GW-22 of Part V-Technical Provisions, revise the first sentence to **“The Supplier shall guarantee ..... for a period of twelve (12) months after the Goods have been installed and commissioned, or 24 months after the last delivery of GOODS to the designated site, whichever period comes first.”**
2. Clause 6.1, under **“Delivery and Documents”**, page IV-SCC-1 of Part IV-Special Conditions of Contract, Delete the whole text of the 1<sup>st</sup> paragraph and revise the 2<sup>nd</sup>, 3<sup>rd</sup> and 4<sup>th</sup> paragraphs, respectively, as follows:

**“Delivery and Documents –**

**The delivery terms applicable to this Contract are delivered to *Mamburao DPP and Pulanglupa DPP, Mindoro*. Risk and title will pass from the Supplier to the PROCURING ENTITY upon receipt and final acceptance of the GOODS at their final destination.**

**Complete delivery of the GOODS shall be made by the supplier within one hundred eighty (180) calendar days reckoned from the Contract effectivity date specified in the Notice to Proceed.**

**Upon delivery of the GOODS to the Project Site, the Supplier shall notify the PROCURING ENTITY and present the following documents to the PROCURING ENTITY:**

- (i) XXXX”

3. Clause 6.1, under **“Transportation”**, pages IV-SCC-2 & -3 of Part IV-Special Conditions of Contract, revise 1<sup>st</sup> and 3<sup>rd</sup> paragraphs, respectively, as follows:

**“Transportation –**

**The Supplier is required under this Contract to transport the GOODS to Mamburao DPP and Pulanglupa DPP, Mindoro as the Project Site. Transport to such place of destination in the Philippines, including insurance and storage, as specified in this Contract, shall be arranged by the Supplier, and related costs shall be included in the Contract Price.**

**GOODS are to .....with GCC Clause 20.**

**The PROCURING ENTITY accepts no liability for the damage of GOODS during transit. Suppliers risk and title will not be deemed to have passed to the PROCURING ENTITY until their receipt and final acceptance at the final destination.”**

4. Change the words or numbers **“twelve (12)”** or **“-12”** to **“multi-cylinder with a minimum of 12”** as applicable on the following pages/sheets:
- a. Part V – Technical Provisions, Page V-GW-2, Clause GW-2.0, 1<sup>st</sup> line of item a.
  - b. Part V – Technical Provisions, Page V-MW-1, Clause MW-2.0, 5<sup>th</sup> line
  - c. Part V – Technical Provisions, Page V-MW-3, Clause MW-3.2, 3<sup>rd</sup> line
5. Change the words **“direct injection”** to **“electronic fuel injection”** on the following pages/sheets:
- a. Part V - Technical Provisions, Page V-GW-2, Clause GW-2.0, 1<sup>st</sup> line of item a.
  - b. Part V – Technical Provisions, Page V-MW-1, Clause MW-2.0, 6<sup>th</sup> line.

For the guidance of all concerned.

(Sgd.)  
**E. P. ANGULUAN**  
Vice President and Chairman  
Bids and Awards Committee