



National Power Corporation

SUPPLEMENTAL/BID BULLETIN No. 1 to the Terms of Reference for the:

**SUPPLY, DELIVERY, INSTALLATION AND TEST OF EMERGENCY 15.5kV
THREE PHASE AUTOMATIC RECLOSER CIRCUIT RECLOSER OF CLAVERIA DPP
PR NO. S1-CLV24-027 / REF. NO. EC241015-AM00445**

14 OCTOBER 2024

All prospective bidders and authorized copyholders of the Terms of Reference (TOR) of the project mentioned above are hereby informed of the changes/clarifications as follows:

SUBMISSION / OPENING OF BIDS	
FROM	TO
15 OCTOBER 2024 9:30 A.M. Kaňao Room	16 OCTOBER 2024 9:30 A.M. Kaňao Room

PRICE PROPOSAL FORM
Please refer to the attached Form comprising of one (1) page: Attachment "F"

CLARIFICATIONS:
The scope of works is for the Supply, Delivery, Installation and Test of 15.5kV Three-Phase Automatic Circuit Recloser for Claveria DPP.

All other terms and conditions shall remain the same. Supplemental clarifications shall only supersede the affected requirements.

For the information and guidance of all authorized copyholders of the Terms of Reference (TOR) and prospective bidders.

For the Bids and Awards Committee:

ATTY. MELCHOR P. RIDULME
Senior Vice-President and COO
Chairman, Bids and Awards Committee

AFG-LOG-002.F05
Rev. No. 1



NATIONAL POWER CORPORATION
Gabriel Y. Itchon Building
Senator Miriam P. Defensor Avenue (formerly BIR Road)
Corner Quezon Avenue, Diliman, Quezon City, Philippines
Website: www.napocor.gov.ph



SUPPLY, DELIVERY, INSTALLATION AND TEST OF EMERGENCY 15.5KV THREE PHASE AUTOMATIC CIRCUIT RECLOSER OF CLAVERIA DPP

PRICE PROPOSAL FORM

ITEM NO	DESCRIPTION	QTY. UNIT	C O D E	UNIT PRICE FOR GOODS AND RELATED SERVICES TO BE SUPPLIED AND DELIVERED					TOTAL PRICE
				(E) Total Price of Goods Delivered up to Philippine Port (Phil. Peso)+	(F) Import Duties & other Levies Imposed by Phil. Govt. (Phil. Peso)	(G) Value Added Tax and other Taxes Imposed by Phil. Govt. (Phil. Peso)	(H) Local Transport from Port to Delivery Site (Phil. Peso)<	(I) Total Unit Price (Phil. Peso) (E+F+G+H)	(J) Local Currency (Phil. Peso) (J = I x C)
(A)	(B)	(C)	(D)	(E)	(F)	(G)	(H)	(I)	(J)
1	15.5KV THREE PHASE AUTOMATIC CIRCUIT RECLOSER Specification: Type: Solid Dielectric Vacuum Interrupter Safety Features: CONTROLLED Arc Fault Venting Type of Test Result: To be included in the delivery Ambient Temp. : -40°C to +55°C Phase : 3 Three Rated Frequency: 60 Hz Nominal Rated Voltage: 13.8KV Maximum Rated Voltage: 15.5KV Rated Continuous Current: 800A Fault Make Capacity RMS: 20Ka Fault Make Capacity Peak: 42Ka Fault Break Capacity : 20Ka Fault Break Capacity Operations : 70 Short Time Current Withstand: 20Ka/3 secs Mainly Active Breaking Capacity:800A Cable Charging Current: 25A Line Charging Current: 5A Impulse Withstand Phase to Earth & phase to Phase :110Kv Impulse Across the Interrupter : 110Kv Power Frequency withstand Phase to Earth (dry) :50KV Power Frequency Across the Interrupter :50KV	1	UNIT						
TOTAL									P _____
(Amount in Words)									

Code	Country of Origin

Note: Final delivery site of spare parts shall be at National Power Corporation, SPUG-BOD, Claveria DPP
Brgy. Poblacion 2, Claveria, Masbate

Name of Bidder:
Signature of Bidder: