

NATIONAL POWER CORPORATION

SUPPLEMENTAL / BID BULLETIN NO. 1

SUPPLY AND DELIVERY OF ELECTRICAL EQUIPMENT AND SPARE PARTS FOR 20MVA MOGPOG SUBSTATION (PR NO. S1-M6924-001/ REF. NO. PB240507-AM00216 - PB2)

10 JUNE 2024

All prospective bidders and authorized copy holders of the Bid Documents of the mentioned project are hereby informed of the following clarifications/changes, to wit:

SECTION VI – TECHNICAL SPECIFICATIONS Item 2 – Battery Bank Charger (VI-TDS-3)		
FROM	ТО	
Battery Bank Charger 125 VDC Output, 480/240VAC Input, 150 Max. Amp.	Battery Bank Charger 125 VDC Output, 240VAC Input, 11 Max. Amp.	

		CAL SPECIFICATION g Arrester, 69kV DS-3)	S
FROM		ТО	
Lightning Arres	ter, 69kV	Lightning Ar	rester
Type:	Y10W-12	Type:	Y10W-12
Rated Voltage	12kV	Rated Voltage	12kV
Reference Voltage	60kV	Reference Voltage	6014

Reference Voltage	60kV				
<u> </u>		Reference Voltage	60kV		
DC 1mA ref. voltage:	≥85kV	DC 1mA ref. voltage:	≥85kV		
Max. Cont. Operating Voltage:	48kV	Max. Cont. Operating Voltage:	10.2kV		
Nominal Discharge Current:	10kA	Nominal Discharge Current:	10kA		
SECTION VI. TECHNICAL OPERISONS					

SECTION VI - TECHNICAL SPECIFICATIONS
TS-5.0 DRAWINGS AND DOCUMENTS TO BE SUBMITTED
Item a.5

CONTACT PERSONNEL FOR THE CONDUCT OF SITE INSPECTION: ENGR. OCTAVEN G. HERRERA Contact No. 0908-1818-683



NATIONAL POWER CORPORATION

Gabriel Y. Itchon Building Senator Miriam P. Defensor-Santiago Avenue (formerly BIR Road) Corner Quezon Avenue, Diliman 1100 Quezon City, Philippines Tel. Nos. (632) 8921-3541 to80 • Fax No. (632) 8921-2468 Website: www.napocor.gov.ph





SUPPLEMENTAL / BID BULLETIN NO. 1
SUPPLY AND DELIVERY OF ELECTRICAL EQUIPMENT AND SPARE PARTS FOR 20MVA MOGPOG SUBSTATION
(PR NO. S1-M6924-001/ REF. NO. PB240507-AM00216-PB2)
Date: 10 June 2024

BID DOCUMENTS SECTION VI – TECHNICAL SPECIFICATIONS TS-3.0 DELIVERY PERIOD AND LOCATION			
FROM	ТО		
The delivery period shall be ONE HUNDRED TWENTY (120) CALENDAR DAYS reckoned from receipt of Notice to Proceed.	ONE HUNDRED FIFTY (150)		

BID DOCUMENTS SECTION VI – TECHNICAL SPECIFICATIONS TS-5.0 DRAWINGS AND DOCUMENTS TO BE SUBMITTED (Clarifications)		
FROM	ТО	
a.4 Authority to Bid shall be current and valid for at least six (6) months from date of bid opening as advertised.		

All other terms and conditions shall remain the same. Supplemental for clarifications shall only supersede the affected requirements.

For the information and guidance of all authorized copyholders of the Bid Documents and prospective bidders.

For the Bids, and Awards Committee:

ATTY. MELCHOR P. RIDULME
Senior Vice-President and COO
and Chairman, Bids and Awards Committee