



National Power Corporation

SUPPLEMENTAL /BID BULLETIN NO. 1 to the Bid Documents for the:

SUPPLY AND DELIVERY OF ELECTRICAL EQUIPMENT AND LINE HARDWARE
FOR OCC. MINDORO S/S & 69KV UNDER PR NO. S1-OCS24-002/REF NO.
PB240709-JD (PB2)

05 SEPTEMBER 2024

All prospective bidders and authorized copyholders of the Bid Documents of the
above-mentioned project are hereby informed of the following changes:

A. BID SUBMISSION/OPENING

FROM	TO
10 September 2024 9:30 A.M. Kaňao Function Room	12 September 2024 9:30 A.M. Kaňao Function Room

B. SECTION VI – PART I – TECHNICAL SPECIFICATION – CLAUSE TS-6.0 (DATA AND DOCUMENTATION TO BE SUBMITTED)

FROM	TO
c.1 "Certificate of Origin" from the Manufacturer <i>for the</i>	c.1 "Certificate of Origin" from the Manufacturer <i>for items 1 & 2 only</i>

C. SECTION VI – PART I – TECHNICAL SPECIFICATION – CLAUSE TS-6.0 (DATA AND DOCUMENTATION TO BE SUBMITTED)

FROM	TO
b.2 Letter of Confirmation from the Manufacturer that a local agent or representative is available to provide "After Sales Service" to the supplied components/parts/accessories	b.2 Letter of Confirmation from the Manufacturer that a local agent or representative is available to provide "After Sales Service" to the supplied components/parts/accessories <i>for</i> <i>items 1 & 2 only.</i>

D. ATTACHMENT 1

See attached Attachment 1 "page 1 – Annex A"



E. ADDITIONAL REQUIREMENTS

See attached Drawings and Colored Pictures/Images "pages 7 - Annex B"

All other terms and conditions shall remain the same.

For the information and guidance of all authorized copyholders of the Bid Documents and prospective bidders.

For the Bids and Awards Committee:



ATTY. MELCHOR P. RIDULME

Senior Vice President & COO
and Chairman, Bids and Awards Committee

ATTACHMENT 1

PR NO. OCS24-002

SUPPLY AND DELIVERY OF POWER TRANSFORMER AND EIGHT (8) OTHER ITEMS

ITEM	DESCRIPTION	QTY		UNIT PRICE	TOTAL PRICE
1	TRANSFORMER 220V, 13800, 3 PHASE DRY TYPE	1	UNIT	900,000.00	900,000.00
2	METER, BILLING ENERGY- DIGITAL COMPLETE W/ ACCESSORIES & INSTRUMENTATION PARTS	4	SET	78,750.00	315,000.00
3	MOTOR CHARGING, 125V	1	UNIT	100,000.00	100,000.00
4	MOTOR CHARGING, 230V	1	UNIT	100,000.00	100,000.00
5	ROD ANCHOR, TWINEYE 3/4 X 8 1X6 SCREW ANCHOR	100	PCS	1,575.00	157,500.00
6	CLAMP, DEAD END, STRAIN	34	PCS	2,625.00	89,250.00
7	CLAMP PARALLEL GROOVE, GUY-3 BOLT, HD	50	PCS	315.00	15,750.00
8	CONTACTORS 125V	10	PCS	6,000.00	60,000.00
9	CONTACTORS 48V	5	PCS	6,000.00	30,000.00
					1,767,500.00

ADDITIONAL PICTURES (DRAWINGS AND DIMENSIONS)


SECTION VI – TECHNICAL SPECIFICATIONS

1. POWER TRANSFORMER (Dry type indoor control Power Transformer, 100KVA)

Power Transformer cubicle

Existing Power Transformer

100KVA





Mounting of Power Transformer

Legend:

○ - Holes for Power Transformer Base

▮ - Metal Power Transformer Base; C Bar 2" x 4"

▮ - Metal Power Transformer Base; C Bar 1" x 1" x 1/4"



2. BILLING METER



Billing Meter



Meter Box

Lower Terminals
and Test Blocks







Steel Wall Box

3. MOTOR CHARGING (125V)

Applications:

Vacuum Circuit Breaker (13.8KV)





Applications:

SF6 Breaker (69KV)



18 cm.



14 cm.

SHAFTING



8 cm.

8. CONTACTOR (125VDC)

Applications:

Vacuum Circuit Breaker (13.8KV)

**NOTE: FOR SHAFT
DIAMETER SIZE IS 8 CM.**



9. CONTACTOR (48VDC)

Applications:

SF6 Breaker (69KV)

