



# NATIONAL POWER CORPORATION

## SUPPLEMENTAL / BID BULLETIN NO.1

### SUPPLY AND DELIVERY OF MECHANICAL SPARE PARTS FOR 300KW CUMMINS GENSET MODEL M-C375 OF PATNANUNGAN DPP UNDER PR NO. S1-PAD25-001 / REF. NO. PB250122-KB00600

14 JANUARY 2025

All prospective bidders and authorized copy holders of the Bid Documents of the mentioned project are hereby informed of the following clarifications/changes, to wit:

<b>BID DOCUMENTS SECTION VI – TECHNICAL SPECIFICATIONS</b>	
<b>TS-2.0 SCOPE OF WORKS</b>	
From;	To:
The scope of work shall cover the SUPPLY AND DELIVERY OF MECHANICAL SPARE PARTS FOR 300KW CUMMINS GENSET MODEL M-C375 OF PATNANUNGAN DPP	The scope of work shall cover the SUPPLY AND DELIVERY OF MECHANICAL SPARE PARTS FOR 300KW CUMMINS GENSET MODEL M-C375 (SN. 41270962) OF PATNANUNGAN DPP
<b>TS-2.0 SCOPE OF WORKS, Item No. 9</b>	
From;	To:
Radiator Assembly for 300kW Cummins	Radiator Assembly for 300kW Cummins (Model: BWXK 19450, SN BD1703054 05) See attached drawings
<b>TS-2.0 SCOPE OF WORKS, Item No. 13</b>	
From;	To:
STATOR, MAIN STATOR FOR 300KW CUMMINS	STATOR, MAIN STATOR FOR 300KW CUMMINS (Model: LSA 46.3L10 C 6/4; SN718242 001)
<b>TS-5.0 DRAWINGS AND DOCUMENTS TO BE SUBMITTED a.2</b>	
From;	To:
Authorization to bid from any of the following	Authorization to bid from any of the following (except for item no. 13)
<b>TS-5.0 DRAWINGS AND DOCUMENTS TO BE SUBMITTED b.1</b>	
From;	To:
"Certificate of Origin" of the spare parts /equipment as stated in the PR	"Certificate of Origin" of the spare parts /equipment as stated in the PR (except for item no. 13)

The NPC confirms that the radiator assembly, whether designed for 40°C or 50°C, is suitable for operation. Furthermore, certificates from the OEM shall be valid upon bid submission.

All other terms and conditions shall remain the same. Supplemental for clarifications shall only supersede the affected requirements.

For the information and guidance of all authorized copyholders of the Bid Documents and prospective bidders.

For the Bids and Awards Committee:

**LARRY I. SABELLINA**

Vice-President, Mindanao Generation  
and Chairman, Bids and Awards Committee




#### NATIONAL POWER CORPORATION


Gabriel Y. Itchon Building  
Senator Miriam P. Defensor-Santiago Avenue (formerly BIR Road)  
Corner Quezon Avenue, Diliman 1100 Quezon City, Philippines  
Tel. Nos. (632) 8921-3541 to 80 • Fax No. (632) 8921-2468  
Website: [www.napocor.gov.ph](http://www.napocor.gov.ph)




Technical Specification of KTA19-G2 Radiator Assembly







Sale!



**Red copper cummins  
cooling system radiator  
KTA19-G2**