



National Power Corporation

SUPPLEMENTAL /BID BULLETIN NO. 3

to the Bid Documents for the:

**SUPPLY AND DELIVERY OF ELECTRICAL EQUIPMENT AND LINE HARDWARE
FOR OCC. MINDORO S/S & 69KV UNDER PR NO. S1-OCS24-002/REF NO.
PB240709-JD**

11 JULY 2024

All prospective bidders and authorized copyholders of the Bid Documents of the above-mentioned project are hereby informed of the following changes:

A. SECTION VII – SCHEDULE OF REQUIREMENTS

FROM	TO
TRANSFORMER 3-PHASE DRY TYPE RATING/FREQUENCY: 30KVA/60HZ PRIMARY: 13,800VAC SECONDARY: 230VAC MOUNTING: METAL CLAD SWITCHGEAR	TRANSFORMER 3-PHASE DRY TYPE RATING/FREQUENCY: 100KVA/60HZ PRIMARY: 13,800VAC SECONDARY: 230VAC MOUNTING: METAL CLAD SWITCHGEAR

B. SEE ATTACHED REVISED DRAWING FOR POWER TRANSFORMER “PAGE 1 - ANNEX A”

All other terms and conditions shall remain the same.

For the information and guidance of all authorized copyholders of the Bid Documents and prospective bidders.

For the Bids and Awards Committee:



ATTY. MELCHOR P. RIDULME

Senior Vice President & COO

and Chairman, Bids and Awards Committee



AFG-LOG-002.F05

Rev. No. 1

Page 1 of 1

NATIONAL POWER CORPORATION

Gabriel Y. Itchon Building

Senator Miriam P. Defensor-Santiago Avenue (formerly BIR Road)

corner Quezon Avenue, Diliman, Quezon City 1100, Philippines

Tel. Nos. (632) 8921-3541 to 80 • Fax No. (632) 8921-2468

Website: www.napocor.gov.ph



ADDITIONAL PICTURES (DRAWINGS AND DIMENSIONS)

SECTION VI – TECHNICAL SPECIFICATIONS

1. POWER TRANSFORMER (Dry type indoor control Power Transformer, 100KVA)

Power Transformer cubicle

Existing Power Transformer
100KVA

