



National Power Corporation

SUPPLEMENTAL / BID BULLETIN NO. 2022-GOODS-050

to the Bidding Documents for the:

SURGE ARRESTER, MEDIUM VOLTAGE FOR UNITS 3, 4 & 5, A6EE

(MG-A7C22-007/ PB-2022-008, ITEM NO. 3)

(Published on May 18, 2022, PhilGEPS)

All prospective bidders are hereby informed of the changes in some provisions of the tender documents as follows:

Clarifications:

1. Changes in Section VII Conformity with the Technical Specifications- 2:

FROM		TO	
Rated Voltage	At least 17 kV	Rated Voltage	17 – 20 kV
Temperature Class	Class F	Temperature Class	Class 2
MCOV:	15.3 kV	MCOV:	15.0 - 16 kV
1.2/50µs Impulse discharge Voltage:	54 kV	1.2/50µs Impulse discharge Voltage:	Not to exceed 125 kV
8.0/20µs Lightning Impulse residual Voltage:	54 kV	8.0/20µs Lightning Impulse residual Voltage:	Not to exceed 54 kV at 10 kA discharge current

2. Measurement/Nominal Dimension of Surge Arrester:

- a. Height of Surge Arrester – Not to exceed 470 mm
- b. Dimension – designed for 13.8 kV indoor application and/or 13.8 kV system indoor standard creepage distance

Notes:

- 1. All other terms published in the previous publication that are not amended by this publication shall remain the same.
- 2. For further clarification, you may contact us at (063)223-4604

For the information and guidance of all concerned



REYNANTE T. CIRUELA
 Chairman
 Bids and Awards Committee
 Mindanao Generation

Date of Publication: May 30, 2022



Management System
ISO 9001:2015
www.tuv.com
ID: 810886256

