.....



# TERMS OF REFERENCE ALTERNATIVE MODE OF PROCUREMENT

(SMALL VALUE PROCUREMENT - 53.9)

1.Scope of Works (REF:	PR NO.	S3-SPUGEM22-009	S3-KDP22-024 8
028-030)			

## "REQUEST FOR JOB ORDERS: VARIOUS REPAIRS AND MAINTENANCE ON VARIOUS ENGINE PARTS INTENDED FOR KALAMANSIG DPP"

	ENGINE PARTS INTENDED FOR KALAMANSIG DPP			
ITEM NO.	DESCRIPTION OF ITEM/S	QUANTITY	UNIT	TOTAL ABC (Php)
	REQUEST FOR JOB ORDERS: VARIOUS REPAIRS AND MAINTENANCE ON VARIOUS ENGINE PARTS INTENDED FOR KALAMANSIG DPP	1	LOT	450,000.00
	S3-KDP22-024 (03/02/2022) (F3552S3)			
1	REQUEST FOR JOB ORDER: REPAIR AND MACHINING OF CYLINDER HEADFOR 600KW PERKINS INTENDED FOR KALAMANSIG DPP	1	LOT	100,000.00
	TO FURNISH LABOR, PARTS, TOOLS AND EXPERTISE FOR THE REPAIR AND MACHINING OF 600KW PERKINS GENSET			
	SCOPE OF WORKS TO BE DONE:			
	1. CONDUCT CYLINDER HEAD CRACK TEST			
	2. CONDUCT HEAD RESURFACE			
	3. CONDUCT VALVE SEAT AND REPLACE			
	4. CONDUCT VALVE SEAT RING AND REPLACE			
	5. REPLACEMENT OF VALVE GUIDE			
	6. CONDUCT CYLINDER HEAD PLUG WELDING			
	S3-KDP22-028 (03/03/2022) (F3554S3)			
2	REQUEST FOR JOB ORDER: REPAIR AND MAINTENANCE OF TWO (2) UNITS STARTER MOTOR OF 600KW PERKINS INTENDED FOR KALAMANSIG DPP	1	LOT	100,000.00
	TO FURNISH LABOR, MATERIALS AND MANPOWER EXPERTISE FOR THE REPAIR TWO (2) UNITS STARTER MOTOR OF 600KW PERKINS OF KALAMANSIG DPP			
	SCOPE OF WORKS TO BE DONE:			
	1. CONDUCT GENERAL SERVICES OF STARTER			
	2. REPLACE BRAND NEW CARBON BRUSHES			
	3. CONDUCT REPLACEMENT OF WIRES AND REWINDING OF DAMAGED MOTOR WINDINGS			
	4. REPAIR/MACHINING OF DAMAGE STARTER MOTOR GEAR TEETH			
	S3-KDP22-029 (03/02/2022) (F3553S3)			
3	REQUEST FOR JOB ORDER: REPAIR AND MAINTENANCE OF ONE (1) UNIT TURBO CHARGER FOR 600KW PERKINS GENSET INTENDED FOR KALAMANSIG DPP	1	LOT	100,000.00
	SCOPE OF WORKS TO BE DONE:			
	a. STANDARD & BALANCING OF IMPELLER SHAFT			
	b. CHECK UP & RE-STANDARD OF TURBO HOUSING.			
	c. CHECK & RE-STANDARD OF TURBINE HOUSING			
	d. RE-STANDARD OF INTAKE HOUSING.			
	e. RE-STANDARD OF EXHAUST HOUSING.			
1	PARTS TO BE REPLACED:	1	1	

Page 2 of 5

-----

	a. 1 REPAIR KIT 600KW DALE PERKINS b. 1 UNIT TURBINE WHEEL ASSEMBLY 600KW PERKINS			
	S3-KDP22-030 (03/03/2022) (F3549S3)			
4	REQUEST FOR JOB ORDER: REPAIR AND MAINTENANCE OF ONE (1) UNIT RADIATOR FOR 600KW PERKINS AND TWO (2) UNITS 560KW PERKINS GENSETS INTENDED FOR KALAMANSIG DPP	1	LOT	150,000.00
	SCOPE OF WORKS TO BE DONE			
	CONDUCT DESCALING ON THE RADIATOR TUBES AND CONDUCT     OVERHAUIL			
	2. SOLDERED LEAKS ON THE RADIATOR			
	3. CONDUCT REPAIR ON THE RADIATOR COVER UPPER AND BELOW			
	4. HYDROSTATIC TEST FOR 3 HRS. AT 1.5X POPPING PRESSURE OF THE RELIEF VALVE INTEGRAL TO THE FILLER CUP			
	TOTAL BID PRICE			450,000.00
	Notes:			
	Bid offer must be within the ABC  Warranty shall be at least Six (6) MONTHS.			

Note: This portion must include the complete technical specifications and the quantity of the requirement.

## 2. Delivery Period / Duration of Work

Delivery Period / Duration of Work shall not be later than <u>Thirty (30)</u> calendar days upon <u>receipt</u> of the Purchase Order/Contract or Notice to Deliver.

#### 3. Delivery Point

PLANT SITE, KALAMANSIG DPP

#### 4. Bid Submission

The Bidder shall submit their sealed quotations through their authorized representative to be dropped in the designated drop box in the <a href="SPUG Mindanao Central Office">SPUG Mindanao Central Office</a>, <a href="Kumintang St.">Kumintang St.</a>, <a href="Mindanao City">Mintal</a>, <a href="Tugbok District">Tugbok District</a>, <a href="Davao City">Davao City</a>

## 5. Late Bids

Any Bid submitted after the deadline for submission and receipt of Bids shall not be accepted by NPC.

#### 6. Bid Prices

The bid price as indicated in the Quotation Form shall be fixed during the Bidder's performance of the Contract and not subject to variation or price escalation on any account. A Bid submitted with an adjustable price quotation shall be treated as non-responsive.

## 7. Bid Price Validity

Price Validity shall not be less than One Hundred Twenty (120) calendar days from date of bid submission.

## 8. Eligibility Criteria

- a. Bids shall be checked using the PASS / FAIL Criteria for Legal, Technical and Financial components.
- b. From the bids that were rated PASSED, the same shall be ranked and corrected for computational errors to identify the Single / Lowest Calculated Bid (S/LCB).

#### 9. Detailed Evaluation and Comparison of Bids

The S/LCB shall be subjected to detailed evaluation against the Technical Specifications including arithmetical computations. Documents which are deemed not to comply with the requirements of the tender shall be considered non-complying.

## 10. Post qualification

- a. Submitted documents of the S/LCB shall be subjected to post qualification evaluation.
- b. The bid that PASSED the Post-Qualification shall be declared as the Single/Lowest Calculated Responsive Bid (S/LCRB).

#### 11. Total Contract Price

The Total Contract Price shall be inclusive of all taxes and other related expenses/charges.

## 12. Notice to Supplier

- a. The supplier shall pick-up the Purchase Order (PO)/ Notice to Proceed (NTP) from NPC within two (2) calendar days from receipt of the Notice of Award.
- b. Failure to secure the PO/NTP by the supplier within the said period will mean cancellation of the same and imposition of penalties as prescribed by law.

## 13. PO Effectivity

Small Value Procurement- 53.9 (PR No. <u>S3-SPUGEM22-009 (S3-KDP22-023-024 & 028-030)</u>

Page 3 of 5

-----

The PO Shall take effect immediately upon receipt of the PO / NTP by the supplier sent through fax as evidenced by the fax transmission receipt and as confirmed by the supplier's representative.

## 14. Terms of Payment

Terms of Payment shall be **Thirty (30) days** after submission of complete supporting documents.

#### 15. Warranty

Unless otherwise provided in the RFQ, the warranty period shall be a minimum of <u>Six (6) Months</u> from the date of final acceptance by the end-user.

## 16. Liquidated Damages

Where the supplier refuses or fails to satisfactorily complete the work within the specified contract time, plus any time of extension duly granted and is hereby in default under the contract, the supplier shall pay NPC for liquidated damages, and not by way of penalty, an amount equal to at least one tenth (1/10) of one percent (1%) of the cost of the undelivered/unperformed portion of the items/works for every day of delay. Once the cumulative amount of liquidated damages reaches ten percent (10%) of the amount of the contract, the procuring entity may rescind or terminate the contract, without prejudice to other courses of action and remedies open to it (Section 68 of the Revised IRR of RA 9184).

## 17. Liability of the Supplier

If after signing and accepting the Purchase Order/Contract, the supplier fails to deliver the goods and/or services, appropriate sanctions will be imposed as prescribed under Republic Act (RA) 9184 and its Revised Implementing Rules and Regulations (IRR).

#### 18. Reservation Clause

NPC reserves the right to accept or reject any bid, to annul the bidding process, and to reject all bids at any time prior to contract award, without thereby incurring any liability to the affected bidder/s.

SUPPLIER'S BID QUOTATION

To: The DBAC Chairman:

I have read and examined the Terms of Reference for Purchase Requisition (PR) No/s. <u>\$3-\$PUGEM22-009 (\$3-KDP22-023-024 & 028-030)</u>. I agree with the conditions of the TOR and offer the following with specific description:

(NP-SMALL VALUE PROCUREMENT53.9)

	The renewing with openine description.	1	1	Ī		1
ITEM NO.	DESCRIPTION OF ITEM/S TO BE SUPPLIED (INCLUDE BRAND NAME)	OFFERED BRAND/ MODEL	QTY.	UNIT of MEASURE	UNIT PRICE (Php)	TOTAL PRICE (Php)
	REQUEST FOR JOB ORDERS:					
	VARIOUS REPAIRS AND					
	MAINTENANCE ON VARIOUS ENGINE					
	PARTS INTENDED FOR					
	KALAMANSIG DPP					
	S3-KDP22-024 (03/02/2022) (F3552S3)					
1	REQUEST FOR JOB ORDER: REPAIR AND MACHINING OF CYLINDER HEADFOR 600KW PERKINS INTENDED FOR KALAMANSIG DPP		1	LOT		
	TO FURNISH LABOR, PARTS, TOOLS AND					
	EXPERTISE FOR THE REPAIR AND MACHINING					
	OF 600KW PERKINS GENSET  SCOPE OF WORKS TO BE DONE:		1			
	1. CONDUCT CYLINDER HEAD CRACK TEST					
	2. CONDUCT HEAD RESURFACE					
	3. CONDUCT VALVE SEAT AND REPLACE					
	4. CONDUCT VALVE SEAT RING AND REPLACE					
	5. REPLACEMENT OF VALVE GUIDE					
	6. CONDUCT CYLINDER HEAD PLUG WELDING					
	S3-KDP22-028 (03/03/2022) (F3554S3)					
	REQUEST FOR JOB ORDER: REPAIR					
2	AND MAINTENANCE OF TWO (2) UNITS STARTER MOTOR OF 600KW PERKINS		1	LOT		
	INTENDED FOR KALAMANSIG DPP					
	TO FURNISH LABOR, MATERIALS AND					
	MANPOWER EXPERTISE FOR THE REPAIR TWO					
	(2) UNITS STARTER MOTOR OF 600KW PERKINS OF KALAMANSIG DPP					
	SCOPE OF WORKS TO BE DONE:					
	1. CONDUCT GENERAL SERVICES OF STARTER					
	2. REPLACE BRAND NEW CARBON BRUSHES					
	3. CONDUCT REPLACEMENT OF WIRES AND					
	REWINDING OF DAMAGED MOTOR WINDINGS					
	4. REPAIR/MACHINING OF DAMAGE STARTER					
	MOTOR GEAR TEETH					
	S3-KDP22-029 (03/02/2022) (F3553S3)					
	REQUEST FOR JOB ORDER: REPAIR					
0	AND MAINTENANCE OF ONE (1) UNIT			LOT		
3	TURBO CHARGER FOR 600KW PERKINS GENSET INTENDED FOR KALAMANSIG		1	LOT		
	DPP					
	SCOPE OF WORKS TO BE DONE:					
	a. STANDARD & BALANCING OF IMPELLER SHAFT	1				
	b. CHECK UP & RE-STANDARD OF TURBO					
	HOUSING.					
	c. CHECK & RE-STANDARD OF TURBINE					
	HOUSING					
	d. RE-STANDARD OF INTAKE HOUSING.					

TERMS OF REFERENCE Small Value Procurement- 53.9 (PR No. S3-SPUGEM22-009 (S3-KDP22-023-024 & 028-030) Page 5 of 5

	e. RE-STANDARD OF EXHAUST HOUSING.					
	PARTS TO BE REPLACED:					
	1. 1 REPAIR KIT 600KW DALE PERKINS					
	2. 1 UNIT TURBINE WHEEL ASSEMBLY 600KW					
	PERKINS					
	S3-KDP22-030 (03/03/2022) (F3549S3)					
	REQUEST FOR JOB ORDER: REPAIR					
	AND MAINTENANCE OF ONE (1) UNIT					
4	RADIATOR FOR 600KW PERKINS AND		1	LOT		
4	TWO (2) UNITS 560KW PERKINS			LOI		
	GENSETS INTENDED FOR KALAMANSIG					
	DPP					
	SCOPE OF WORKS TO BE DONE					
	1. CONDUCT DESCALING ON THE RADIATOR					
	TUBES AND CONDUCT OVERHAUIL					
	2. SOLDERED LEAKS ON THE RADIATOR					
	3. CONDUCT REPAIR ON THE RADIATOR COVER					
	UPPER AND BELOW					
	4. HYDROSTATIC TEST FOR 3 HRS. AT 1.5X					
	POPPING PRESSURE OF THE RELIEF VALVE					
	INTEGRAL TO THE FILLER CUP					
	TOTAL BID PRICE					
Notes:						
•M	ode of award is on per lot basis.					
	d offer must be within the ABC per item.					
	Delivery Period : 30 days		Price V	alidity :	120 calenda	ar davs
	Delivery Point : PLANT SITE KALAMAN	ISIG DPP		ty Period :		

Delivery Point : PLANT SITE, KALAMANSIG DPP Warranty Period : Six (6) MONTHS
Terms of Payment : 30 days

Name and Signature of Authorized Representative
Date
Company Name

Note: The bidder may use this form or its own company letter head following this format duly signed by the authorized representative when making the offer.