



National Power Corporation

SUPPLEMENTAL/BID BULLETIN NO. 1

to the Bid Documents for the:

**SUPPLY, DELIVERY, ERECTION, INSTALLATION, TESTING AND COMMISSIONING OF 7.97/13.8KV
DISTRIBUTION LINE (EXTENSION) FOR DIBAY DILAM DPP, DILAM-CAGAYAN
PR NO. HO-PIB25-001 / REF. NO. PB250120-AM00584 (EPA)**

16 DECEMBER 2024

All prospective bidders and authorized copyholders of the Bid Documents of the project mentioned above are hereby informed of the changes/clarifications as follows:

SECTION VI – TECHNICAL SPECIFICATIONS PART II – TECHNICAL DATA SHEETS B.7.5 –Household Wirings 4. Branch Circuit Conductor <u>Operating Temperature, °C</u>	
(VI-EW-2-10)	
FROM	TO
90 °C	at least 60 °C

SECTION III – BID DATA SHEETS ITEM 10.6 - TO BE SUBMITTED DURING BID OPENING (III-BDS-2) and SECTION VIII-BIDDING FORMS - CHECKLIST OF TECHNICAL & FINANCIAL ENVELOPE REQUIREMENTS FOR BIDDERS
(Notes: To be included as requirement)
CERTIFICATE OF SITE INSPECTION DULY SIGNED BY NPC AUTHORIZED OFFICIAL/PERSONNEL

CONTACT PERSON FOR THE CONDUCT OF SITE INSPECTION
<p>➤ Contact Person: Mr. EDUARDO T. MALLARE Officer-in-Charge, PMD</p> <p>➤ Contact Number: 0927 9593626</p>

All other terms and conditions shall remain the same. Supplemental for clarifications shall only supersede the affected requirements.

For the information and guidance of all authorized copyholders of the Bid Documents and prospective bidders.

For the Bids and Awards Committee:


ATTY. MELCHOR P. RIDULME

Senior Vice-President and COO
Chairman, Bids and Awards Committee

AFG-LOG-002.F05
Rev. No. 1



NATIONAL POWER CORPORATION

Gabriel Y. Itchon Building
Senator Miriam P. Defensor Avenue (formerly BIR Road)
Corner Quezon Avenue, Diliman, Quezon City, Philippines
Website: www.napocor.gov.ph

