



NATIONAL POWER CORPORATION

SUPPLEMENTAL / BID BULLETIN NO. 2

**SUPPLY AND DELIVERY OF 69KV LINE LIGHTNING PROTECTION DEVICES FOR NORTHERN PALAWAN SUBSTATION AND TRANSMISSION LINE
PR NO. S1-NPS25-002 / REF. NO. PB241216-AM00568 (EPA)**

**SUPPLY AND DELIVERY OF 69KV LINE LIGHTNING PROTECTION DEVICES FOR SOUTHERN PALAWAN SUBSTATION AND TRANSMISSION LINE
PR NO. S1-SPS25-002 / REF. NO. PB241216-AM00569 (EPA)**

10 JANUARY 2025

All prospective bidders and authorized copy holders of the Bid Documents of the mentioned project are hereby informed of the following clarifications/changes, to wit:

SUBMISSION / OPENING OF BIDS	
FROM	TO
Postponed until further notice per Supplemental Bid Bulletin No. 1 dated 11 December 2024	23 JANUARY 2025 9:30 A.M. / Kanao Room

SECTION III - BID DATA SHEET ITB CLAUSE 5.3 (III-BDS-1)	
FROM	TO
For this purpose, similar contracts shall refer to the Supply and Delivery of Line Lightning Protection Devices for Distribution/Transmission Line.	For this purpose, similar contracts shall refer to the Supply and Delivery of Line Lightning Protection Devices for Sub-Station/Distribution/Transmission Line.

<p>SECTION VI - TECHNICAL SPECIFICATIONS</p> <p>ITEM 5.0 - DRAWINGS AND DOCUMENTS TO BE SUBMITTED</p> <p>a. To be submitted with the bid</p> <p>SECTION III - BID DATA SHEET (ITB Clause 10.5)</p> <p>SECTION VIII-BIDDING FORMS - CHECKLIST OF TECHNICAL & FINANCIAL ENVELOPE REQUIREMENTS FOR BIDDERS (Data and Information to be submitted with the Bid Proposal as specified in the Clause 5.0 of Section VI-Technical Specifications (if any or if applicable))</p>
<p>CERTIFICATE OF SITE INSPECTION</p> <p>DULY SIGNED BY NPC AUTHORIZED OFFICIAL/PERSONNEL</p>



NATIONAL POWER CORPORATION
Gabriel Y. Itchon Building
Senator Miriam P. Defensor-Santiago Avenue (formerly BIR Road)
Corner Quezon Avenue, Diliman 1100 Quezon City, Philippines
Tel. Nos. (632) 8921-3541 to80 • Fax No. (632) 8921-2468
Website: www.napocor.gov.ph



SUPPLEMENTAL BID BULLETIN NO. 2

PR NO. S1-NPS25-002 / REF. NO. PB241216-AM00568 (EPA)

PR NO. S1-SPS25-002 / REF. NO. PB241216-AM00569 (EPA)

DATE: 10 JANUARY 2025

SECTION VI – TECHNICAL SPECIFICATIONS

PART I – TECHNICAL SPECIFICATIONS

TS-3.0 DELIVERY PERIOD AND LOCATION

FROM	TO
The delivery period shall be NINETY (90) CALENDAR DAYS reckoned from receipt of Notice to proceed.	The delivery period shall be ONE HUNDRED FIFTY (150) CALENDAR DAYS reckoned from receipt of Notice to proceed.

SECTION VI – TECHNICAL SPECIFICATIONS

PART I – TECHNICAL SPECIFICATIONS (TS-2.0 SCOPE OF WORKS) –ITEM 1

PART II – TECHNICAL DATA SHEETS - (1.0 SPARE PARTS DATA) –ITEM 1

SECTION VII – SCHEDULE OF REQUIREMENTS (BID PRICE SCHEDULE)

(QTY. - UNIT)

CLARIFICATIONS:

Quantity: 20 set

1 set is composed of the ff:

- 1 unit of LLPD d69z, up to 72,5 kV lines, BFO and DLS protection, PPS frame, set of 4 "rings", Pack size: 1 set/box
- 1 unit of Insulator for LLPD d69z (3 sections), socket / ball eye (size 20 according to IEC60120), Specific load 160kN | Routine load 80kN, Creepage distance, mm – 1730
- 1 set Installation accessories as needed for adoption of the above LLPD set to the existing installation. Site inspection is needed to determine the needed accessories.

SECTION VI – TECHNICAL SPECIFICATIONS

PART II TECHNICAL DATA SHEETS

1.0 SPARE PARTS DATA


CLARIFICATIONS:

50% Flashover voltage (75+75+115 mm air gap), kV, <400

All other terms and conditions shall remain the same. Supplemental for clarifications shall only supersede the affected requirements.

For the information and guidance of all authorized copyholders of the Bid Documents and prospective bidders.

For the Bids and Awards Committee:


LARRY I. SABELLINA
Vice-President, Mindanao Generation
and Chairman, Bids and Awards Committee