



NATIONAL POWER CORPORATION

SUPPLEMENTAL /BID BULLETIN NO. 3

to the Bid Documents for the:

SUPPLY AND DELIVERY OF CURRENT TRANSFORMERS AND POTENTIAL TRANSFORMERS FOR MASBATE MINI-GRID PLANTS UNDER BOD UNDER PR NO. S1-MMG25-003 / REF. NO. PB241203-NA00523

27 November 2024

All prospective bidders and authorized copy holders of the Bid Documents of the above-mentioned project are hereby advised of changes in the provisions in the bid documents, to wit:

A. ATTACHMENT 1 AND SECTION VI – TECHNICAL SPECIFICATIONS PART I – TECHNICAL SPECIFICATIONS TS-2.0 SCOPE OF WORKS ITEM DESCRIPTION

ITEM	FROM	TO
2	POTENTIAL TRANSFORMER, Outdoor Type, Ratio 8400V/120V (70:1), Rated Voltage: 13.8kV, Frequency: 60Hz, BIL: 24/50/125kV, Accuracy Class: 0.2 or better for IEC Standard or 0.3 or better for ANSI Standard <i>(issued Bid Bulletin No. 2 dated 27 November 2024)</i>	POTENTIAL TRANSFORMER, Outdoor Type, Ratio 8400V/120V (70:1), Rated Voltage: 13.8kV, Frequency: 60Hz, BIL: 15.5/40/125kV , Accuracy Class: 0.2 or better for IEC Standard or 0.3 or better for ANSI Standard

B. SECTION VI – TECHNICAL SPECIFICATIONS PART II – TECHNICAL DATA SHEETS ITEM 12 ACCURACY CLASS

ITEM	DESCRIPTION	NPC REQUIREMENTS	
		FROM	TO
2.0	POTENTIAL TRANSFORMER (PT)		
12	Insulation Level	24/50/125kV	15.5/40/125kV

All other terms and conditions shall remain the same.

For the information and guidance of all authorized copy holders of the Bid Documents and prospective bidders.

For the Bids and Awards Committee:

ATTY. MELCHOR P. RIDULME
Senior Vice President & COO and
Chairman, Bids and Awards Committee

