



National Power Corporation

SUPPLEMENTAL/BID BULLETIN NO. 1

to the Bid Documents for the following projects:

SUPPLY AND DELIVERY OF PARTIAL DISCHARGE ANALYZER AND POWER QUALITY ANALYZER FOR SOUTHERN PALAWAN SUBSTATION AND 69KV TRANSMISSION LINE UNDER PR NO. S1-SPS22-001/ REF. NO. PB220321-NA

15 MARCH 2022

All prospective bidders and authorized copy holders of the Bid Documents of the above mentioned project are hereby advised of the changes in the provision of the Bid Documents, to wit:

A. SECTION III – BID DATA SHEET CLAUSE 19.3 AND SECTION II – INSTRUCTION TO BIDDERS CLAUSE 1. SCOPE OF BID

FROM	TO
<p>The Goods are grouped together in one (1) lot and will be awarded to one (1) Bidder in one complete contract.</p> <p>Partial bid is not allowed. The Goods are grouped in a single lot and the lot shall not be divided into sub-lots for the purpose of bidding, evaluation, and contract award.</p> <p>The Bidders bid offer must be within the ABC of the lot and ABC per item.</p> <p>Bid offers that exceed the ABC of the lot or any of the item, with incomplete price, shall be rejected.</p>	<p><u>Goods shall be evaluated and awarded on a per item basis.</u></p> <p><u>Partial bid per item is not allowed. Bidders shall have the option of submitting a proposal on any or all items and evaluation and contract award will be undertaken on a per item Basis.</u></p> <p><u>The Bidders bid offer must be within the ABC per item.</u></p> <p><u>Bid offers that exceed the ABC of the item(s) the bidder participated in or with incomplete price, shall be rejected.</u></p>

B. CALIBRATION UNDER NIST STANDARD

This equipment has a level of accuracies in each sensor and acoustic measurements. Therefore, equipment calibration and calibration certificate is necessary as indicated in Section VI – Technical Specification Part I Clause 7.0 Documents to be Submitted c. To be submitted before or upon delivery: letter c.4 Calibration Certificate Traceable to National/International Standards.

C. SECTION VI – TECHNICAL SPECIFICATIONS PART II

ITEM	DESCRIPTION	NPC's Requirements	
		FROM	TO
1 Partial Discharge Analyzer	1.18 Accessories 1.18.1 Test Probes	Included	Included <u>if necessary</u>
	1.21 Equipment and Manufacturer's Experience 1.21.2 The same type of equipment being offered should	5	<u>3</u>

BIR Road corner Quezon Avenue, Diliman
1100 Quezon City, Philippines
Tel. Nos. (632) 921-3541 to 79 • Fax No. (632) 921-2468
Website: www.napocor.gov.ph



Management System
ISO 9001:2015



www.tuv.com
ID 9106656265

ITEM	DESCRIPTION	NPC's Requirements	
		FROM	TO
	have been in the actual service for not less than: year		
2 Power Quality Analyzer	2.26 Equipment and Manufacturer's Experience 2.26.2 The same type of equipment being offered should have been in the actual service for not less than: year	5	3


D. SCHEDULE OF BID SUBMISSION/OPENING

FROM	TO
21 March 2022 09:30 A.M. Kanao Room	<u>22 March 2022</u> 09:30 A.M. Kanao Room

All other terms and conditions shall remain the same.

For the information and guidance of all authorized copy holders of the Bid Documents and prospective bidders.

For the Bids and Awards Committee:


ATTY. ROGEL T. TEVES
 Vice President, Power Engineering Services and
 Chairman, Bids and Awards Committee

