



National Power Corporation

**SUPPLEMENTAL / BID BULLETIN NO. 2022-GOODS-044**

to the Bidding Documents for the:

**BUCHHOLZ PROTECTION RELAY**  
**(MG-PAT22-026 / PB-2022-007, ITEM NO. 1)**  
(Published on April 30, 2022, PhilGEPS)

All prospective bidders are hereby informed of the changes in some provisions of the tender documents as follows:

**Clarifications:**

*Changes in Section VII, Conformity with the Technical Specifications-3:*

Description	From	To
Gas accumulation Switching	<ul style="list-style-type: none"><li>Approximately 40 - 60cm<sup>3</sup> (First Warning Alarm)</li><li>200 - 300 cm<sup>3</sup> (Official Alarm)</li></ul>	<ul style="list-style-type: none"><li>Approximately 40 - 60cm<sup>3</sup> or 1 m/s damper setting (First Warning Alarm)</li><li>200 - 300 cm<sup>3</sup> (Official Alarm)</li></ul>
Climate Proof	Offshore	IP65 or better

**Notes:**

1. All other terms published in the previous publication that are not amended by this publication shall remain the same.
2. For further clarification, you may contact us at (063)223-4604.

For the information and guidance of all concerned,

**REYNANTE T. CIRUELA**  
Chairman, Bids and Awards Committee  
Mindanao Generation

*Date of Publication : May 13, 2022*

NPC-009.F17  
Rev.No.1  
Page 1 of 1

BIR Road cor. Quezon Avenue, Diliman  
Quezon City 1100, Philippines  
Tel. Nos (632) 921-3541 to 80  
Fax No. (632) 921-2468



Management  
System  
ISO 9001:2015

